

| Fireworks - Class I Checklist ₍₅₋₁₇₋₁₁₎ | | | FWT Id number | | | | |
|----------------------------------------------------|-------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|--|--|--|--|
| | | | | | | | |
| Life Safety | | | | | | | |
| 1 | IC 22-11-14-4.5 | Total amount, in pounds, of fireworks allowed in the Class 1 structure: b1 – unlimited b2 – unlimited b3 – H-3 unlimited b4 – 500 pounds b4 – 1,000 pounds-sprinkler system required c – 3,000 pounds | | | | | |
| 2 | Sec. 107.2.1 | Required test and inspection records shall be available to the fire code official at all times. | | | | | |
| 3 | Sec. 1003.6 | Clear path of the means of egress, no obstructions or storage. | | | | | |
| 4 | Sec. 1027.5 | Exit emergency lighting being maintained, if required. | | | | | |
| Non-Life Safety | | | | | | | |
| 5 | 675 IAC 12-4-9(a) | The building shall be maintained in accordance with the Indiana Building Code in effect at the time the occupancy classification use began. | | | | | |
| 6 | Sec. 308.2 | No open flames or devices. | | | | | |
| 7 | Sec. 310.2 | NO SMOKING signs to be posted in each building, structure, room, or place in which smoking is prohibited. Such signs shall be conspicuously and suitably located and shall be maintained. | | | | | |
| 8 | Sec. 315.1 | Storage, use and handling of miscellaneous combustible materials shall be in accordance with this section. | | | | | |
| 9 | Sec. 315.2 | Storage of combustible materials in buildings shall be orderly. Storage shall be separated from heaters or heating devices by distance or shielding so that ignition cannot occur. | | | | | |
| 10 | Sec. 315.2.1 | Storage shall be maintained 2 feet or more below the ceiling in nonsprinklered areas of buildings or a minimum of 18 inches below sprinkler head deflectors in sprinklered areas of buildings. | | | | | |
| 11 | Sec. 315.2.2 | Combustible materials shall not be stored in exits or exit enclosures. | | | | | |
| 12 | Sec. 315.2.3 | Combustible material shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms. | | | | | |
| 13 | Sec. 315.2.4 | Attic, under-floor and concealed spaces used for storage of combustible materials shall be protected on the storage side as required for 1-hour fire-resistance-rated construction. Openings shall be protected by assemblies that are self-closing and are of noncombustible construction or solid wood core not less than 1.75 inches (44.5 mm) in thickness. Storage shall not be placed on exposed joists. | | | | | |
| 14 | Sec. 315.3 | Outside storage of combustible materials shall not be located within 10 feet (3048 mm) of a property line. | | | | | |
| 15 | Sec. 315.3.1 | Combustible materials stored or displayed outside of buildings that are protected by automatic sprinklers shall not be stored or displayed under nonsprinklered eaves, canopies or other projections or overhangs. | | | | | |
| 16 | Sec. 315.3.2 | Storage in the open shall not exceed 20 feet (6096 mm) in height. | | | | | |
| 17 | Sec. 605.1 | Identified electrical hazards shall be abated. | | | | | |
| 18 | Sec. 605.2 | Illumination shall be provided for service equipment areas, motor control centers and electrical panelboards. | | | | | |

| | | | | | | | |
|----|---------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|--|--|--|
| 19 | Sec. 605.3 | A working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height shall be provided in front of electrical service equipment. | | | | | |
| 20 | Sec. 605.3.1 | Doors into electrical control panel rooms shall be marked with a plainly visible and legible sign stating ELECTRICAL ROOM or similar approved wording. The disconnecting means for each service, feeder or branch circuit originating on a switchboard or panelboard shall be legibly and durably marked to indicate its purpose unless such purpose is clearly evident. | | | | | |
| 21 | Sec. 605.4 | Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with the ICC Electrical Code shall be prohibited. | | | | | |
| 22 | Sec. 605.4.1 | Relocatable power taps shall be of the polarized or grounded type, equipped with overcurrent protection, and shall be listed. | | | | | |
| 23 | Sec. 605.4.2 | Relocatable power taps shall be directly connected to a permanently installed receptacle. | | | | | |
| 24 | Sec. 605.4.3 | Relocatable power tap cords shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage. | | | | | |
| 25 | Sec. 605.5 | Extension cords and flexible cords shall not be a substitute for permanent wiring. | | | | | |
| 26 | Sec. 605.5.1 | Extension cords shall be plugged directly into an approved receptacle, and, except for approved multiplug extension cords, shall serve only one portable appliance. | | | | | |
| 27 | Sec. 605.5.2 | The ampacity of the extension cords shall not be less than the rated capacity of the portable appliance supplied by the cord. | | | | | |
| 28 | Sec. 605.5.3 | Extension cords shall be maintained in good condition without splices, deterioration or damage. | | | | | |
| 29 | Sec. 605.5.4 | Extension cords shall be grounded when serving grounded portable appliances. | | | | | |
| 30 | Sec. 605.6 | Open junction boxes and open-wiring splices shall be prohibited. | | | | | |
| 31 | Sec. 605.7 | Electrical appliances and fixtures shall be tested and listed. | | | | | |
| 32 | Sec. 605.8 | Electrical motors shall be maintained free from excessive accumulations of oil, dirt, waste and debris. | | | | | |
| 33 | Sec. 605.9 | Temporary wiring for electrical power and lighting installations is allowed for a period not to exceed 90 days. Temporary wiring methods shall meet the applicable provisions of the ICC Electrical Code. | | | | | |
| 34 | Sec. 605.9.1 | Temporary wiring attached to a structure shall be attached in an approved manner. | | | | | |
| 35 | Sec. 605.10 | Portable, electric space heaters shall comply with Sections 605.10.1 through 605.10.4. | | | | | |
| 36 | Sec. 605.10.1 | Only listed and labeled portable, electric space heaters shall be used. | | | | | |
| 37 | Sec. 605.10.2 | Portable, electric space heaters shall be plugged directly into an approved receptacle. | | | | | |
| 38 | Sec. 605.10.3 | Portable, electric space heaters shall not be plugged into extension cords. | | | | | |
| 39 | Sec. 605.10.4 | Portable, electric space heaters shall not be operated within 3 feet of any combustible materials. | | | | | |
| 40 | Sec. 703.2 | Opening protectives shall be maintained in accordance with the rules of the commission. | | | | | |
| 41 | Sec. 906.1 | Portable fire extinguishers shall be installed where required by TABLE 906.1 and where required by local ordinance. | | | | | |
| 42 | Sec. 1011.2 | Exit signs shall be internally or externally illuminated. | | | | | |